



(\*\*) BATTERY connections should be made with at least 2.5mm<sup>2</sup> NYAF type cable. The length of the cables to be used for [+] and [-] terminal connections should not exceed 2 meters.

Title <b>KG-15_Bagl_Semasi_ENG_R1.SchDoc</b>		Aspel San.Tic.Ltd. Ferhatpasa Mah.	
Size: A4	Number:	Revision:R0	Atasehir ISTANBUL
Date : 9.08.2022		Sheet 1 of 1	TR
Drawn : MEP			

